

# KENYA PIPELINE COMPANY LIMITED



KENPIPE PLAZA,  
SEKONDI ROAD,  
OFF NANYUKI ROAD,  
INDUSTRIAL AREA,  
NAIROBI, KENYA.  
P.O.Box 73442 -  
00200,  
TELEPHONE: 254-20-  
2606500  
TELEFAX: 254-20-  
8040188/3540032  
E-mail:  
Info@kpc.co.ke

**KPC/PU/002 – OT/16**

**14<sup>th</sup> March 2017**

**TO: ALL BIDDERS**

Dear Sirs,

**RE: TENDER FOR CLEANING, REPAIR AND EXTENAL REPAINTING OF TANK  
14-TK-301 AT KIPEVU OIL STORAGE FACILITY PS14 - CLARIFICATION I**

Kenya Pipeline Company Limited would like to make the following clarifications as raised during tendering:

	<b>BIDDERS QUERY</b>	<b>KPC RESPONSE</b>
1	<b>Item D4.11-a</b> Replace entire 6" Dia roof drain comprising sump, swivel joint and piping as per clause 3.4.4.3 (a). Please clarify if swivel joints (4) of them need to be supplied new ones. In the past 3 tanks, swivel joints were serviced.	<b>You are required to supply New Swivel Joints</b>
2	<b>Item D4.11 b</b> Allow for testing roof drain swivel joints assembly (materials inclusive). Please clarify what are the materials inclusive of?	<b>They are inclusive of Materials for Testing Swivel Joints Assembly</b>
3	<b>Item F2</b> Reinstall the roof seals (primary and secondary) as in item B3. Can you clarify what you mean by this item? Do you require new seals?	<b>NO we do not require New Roof Seals. Return the Ones Removed</b>

All other terms and conditions of the tender remain the same.

Yours faithfully,

  
**NICHOLAS GITOBU**  
**FOR: MANAGING DIRECTOR**

/jo